



Ref. Certif. No.

US-34605-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

CB TEST CERTIFICATE

Product

Photovoltaic (PV) Module(s)

Name and address of the applicant

FUJIYAMA POWER SYSTEMS PVT LTD
53A/6, RAMA ROAD IND. AREA NEAR SAT GURU RAM SING
MARG METRO STATION, NEAR NDPL GRID OFFICE, DELHI –
110015, INDIA

Address of the manufacturer

53A/6, RAMA ROAD IND. AREA NEAR SAT GURU RAM SING
MARG METRO STATION, NEAR NDPL GRID OFFICE, DELHI –
110015, INDIA

Address of the factory

Block No. 105, B/H Aron Pipes, B/H Hariya Talav, Kim Mandvi
Road, Karanj, Surat-394110, Gujarat
India

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Page 2

Trademark / Brand (if any)



Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

UTL 18 Cell Series: Multi Cell, UTL 36 Cell Series: Multi Cell,
UTL 48 Cell Series: Multi Cell, UTL 54 Cell Series: Multi Cell,
See Page 2

Additional information (if necessary may also be
reported on page 2)

☒ Additional Information on page 2

A sample of the product was tested and found
to be in conformity with

IEC 61730-1:2004/AMD1:2011, IEC 61730-1:2004/AMD2:2013,
IEC 61730-1:2004, IEC 61730-2:2004/AMD1:2011,
IEC 61730-2:2004

As shown in the Test Report Ref. No. which forms part
of this Certificate

NC29473_4789139650_D2 issued on 2019-09-24

This CB Test Certificate is issued by the National Certification Body



- ☒ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☐ UL (Denko), Borupvang 5A DK-2756 Ballerup, DENMARK
- ☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

Date: 2019-10-17

Signature:

For full legal entity names see www.ul.com/ncbnames

Jolanta M. Wroblewska



Ref. Certif. No.

US-34605-UL

Model Details:

UTL 72 Cell Series: Multi Cell

UTL350W72F, UTL345W72F, UTL340W72F, UTL335W72F,
UTL330W72F, UTL325W72F, UTL320W72F, UTL315W72F
UTL310W72F, UTL305W72F, UTL300W72F, UTL250W72C
UTL225W72C, UTL200W72C, UTL180W72C

UTL 60 Cell Series: Multi Cell

UTL280W60F, UTL275W60F, UTL270W60F, UTL265W60F, UTL260W60F, UTL255W60F, UTL250W60F

UTL 54 Cell Series: Multi Cell

UTL225W54F, UTL230W54F, UTL235W54F, UTL240W54F
UTL245W54F, UTL250W54F

UTL 48 Cell Series: Multi Cell:

UTL200W48F, UTL205W48F, UTL210W48F, UTL215W48F
UTL220W48F, UTL225W48F

UTL 36 Cell Series: Multi Cell

UTL10W36C, UTL15W36C, UTL20W36C, UTL30W36C, UTL37W36C
UTL40W36C, UTL50W36C, UTL55W36C, UTL60W36C, UTL75W36C
UTL80W36C, UTL90W36C, UTL100W36C, UTL110W36C, UTL120W36C
UTL125W36C, UTL150W36F, UTL155W36F, UTL160W36F, UTL165W36F

UTL 18 Cell Series: Multi Cell

UTL5W18C, UTL3W18C

Ratings:

72, 60, 54, 48 Cell Series:

Maximum System Voltage: 1000Vdc

Maximum over current protection rating: 20A

36 Cell Series:

Maximum System Voltage: 1000Vdc

Maximum over current protection rating: 15A

36 Cell Series:

Maximum System Voltage: 1000Vdc

Maximum over current protection rating: 10A

36 Cell Series:

Maximum System Voltage: 600Vdc

Maximum over current protection rating: 10A

36 Cell Series:

Maximum System Voltage: 600Vdc

Maximum over current protection rating: 5A

18 Cell Series:

Maximum System Voltage: 600Vdc

Maximum over current protection rating: 3A

"Current ratings may vary"

See specific model rating in General Product information in Test Report.

Additional Information:

Additionally evaluated to EN 61730-1:2007/ A1:2012/ A2:2013/ A11:2014 and EN 61730-2:2007/ A1:2012.

Additional information (if necessary)

UL (US), 333 Plingsien Rd IL 80082, Northbrook, USA

UL (Denko), Borupvang 5A DK 2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 8F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/nbcnames

Date: 2019-10-17

Signature:

Jolanta M. Wroblewska